

NOTES

1. READ THIS DRAWING IN CONJUNCTION WITH RELEVANT ARCHITECTURAL AND STRUCTURAL DRAWINGS AND REPORT ANY DISCREPANCIES TO THE ENGINEER.
2. ALL REINFORCED CONCRETE TO BE 1 : 1.5 : 3 MIX ( CLASS 25/20 ), and ALL MASS CONCRETE TO BE CLASS C15
3. ALL AGGREGATE TO BE FROM AN APPROVED QUARRY.
4. COVER TO REINFORCEMENT TO BE 25mm IN BOTH BEAMS AND SLAB and 50MM IN THE BASE
5. USE FOURED DIMENSIONS ONLY DO NOT SCALE. ALL DIMENSIONS IN MILLIMETRES
6. REINFORCEMENT LAP LENGTH TO BE
- T10 - 500  
T12 - 540  
T16 - 720  
T20 - 950
7. VERTICAL REBARS TO BE DOWELLED
8. FLOOR SLAB REINFORCED WITH A98 35mm FROM THE TOP.
9. REINFORCEMENT TO BE CHECKED AND APPROVED BEFORE PROCEEDING WITH POURING OF CONCRETE

DO NOT SCALE OFF FROM THIS DRAWING. CONTRACTOR MUST CHECK ON SITE. ALL DIMENSIONS AND INFORMATION PROVIDED. ANY QUERIES OR DISCREPANCIES MUST BE REFERRED TO THE PROJECT ARCHITECT BEFORE MATERIALS ARE BOUGHT OR WORK PUT IN HAND.

THE CONTRACTOR IS RESPONSIBLE FOR THE STRUCTURAL STABILITY AND EFFICIENT PERFORMANCE OF HIGHER WORK.



MALAWI GOVERNMENT  
BUILDINGS DEPARTMENT  
PRIVATE BAG B 365  
LILONGWE 3.

Tel: 01 788 742 Fax: 01 788 259 E-mail: buildings.department@malawi.net

| No. | DESCRIPTION | BY | DATE |
|-----|-------------|----|------|
|-----|-------------|----|------|

REVISIONS



THE CHIEF EXECUTIVE OFFICER  
MALAWI ENERGY REGULATORY AUTHORITY  
PRIVATE BAG B-496  
CAPITAL CITY  
LILONGWE 3.

PROJECT TITLE

STANDARDS AND REQUIREMENTS FOR  
CONSTRUCTION OF URBAN FILLING  
STATION


CLIENT

MALAWI ENERGY REGULATORY AUTHORITY


DRAWING NAME

DRIVE WAY SECTIONS


| DESIGNED & DRAWN | DATE                | SCALE         |
|------------------|---------------------|---------------|
| L. MPHALASA      | MARCH 2020          | AS SHOWN      |
| CHECKED          | CHIEF STR. ENGINEER | D.O.B         |
| J. MUSOPOLE      | C.M. MULAGA         | H.J.K. CHUDZU |
| PROJECT ENGINEER | PROJECT NUMBER      |               |
| J. MUSOPOLE      | .....               |               |
| FILE NUMBER      | DRAWING             |               |
|                  |                     |               |




SECTION F-F THROUGH CULVERT  
Scale 1: 25



KERB TYPE A (UPSTAND KERB)  
Scale 1 : 10



SECTION E-E: Through forecourt  
Scale 1: 25



SECTION D-D: Through Driveway  
Scale 1: 25